

C.S.

No. 802

Ag: Clerk to Bd of Health.

SUBJECT.

1920

21st October.

Previous Paper.

Reports on the condition of stone drain on the north side of Drury Street.

MINUTES. (1)

Colonial Engineer,

Will you please examine this drain and report?

R.B.B.
for C. S.
21/10/20.

(2)

The Hon: Col: Secretary.

The bottom of this drain is faulty and as soon as sand and shingle can be obtained the work of repairing same will put in hand.

(3)

R.B.B.
C.E.

10/11/20.

*H.E. Submitted
for C.S.
10/11/20*

(4)

Drain approved. Inform Col. Eng. accordingly.

(5)

Colonial Engineer.

W.D.W.
11. 11. 20

Subsequent Paper.

*To write
for C.S.
12. 11. 20*

The Hon: Col: Secretary.

Noted.

P.M.S.
C.F. 12/11/20.

BOARD OF HEALTH,

STANLEY.

21st October 1920.

Sir,


At a meeting of the Board of Health held on the 19th instant, it was reported that the stone drain on the north side of Drury Street is in need of repair. It appears that the sides and bottom of the drain are cracked and in places broken, and some of the drainage is finding its way through the cracks on to the adjoining land.

The Board would be glad if you would ask the Colonial Engineer to examine the drain, and have the necessary repairs effected as soon as possible.

I have the honour to be,

Sir,

Your obedient servant,



Ag. Clerk to the Board.

THE HONOURABLE

THE COLONIAL SECRETARY,

STANLEY.

800/20.

12th November

20.


Sir,

I am directed by the Administrator to acknowledge the receipt of your letter of the 21st October, 1930, regarding the condition of the stone drain on the north side of Drury Street, and to inform you that His Excellency has given instructions to have the repair of this drain put in hand at an early date.

I am,

Sir,

Your obedient servant,


for Colonial Secretary.

The Clerk to the Board of Health,
Stanley.